



dbS contracting

Electrical Fire Data OH & S Audits

PH: 0413 081 991 PO Box 344 Terrey Hills 2084 ABN:58142038364 LIC: 236801C

SAMPLE CERTIFICATE

Certificate of Compliance - Essential Fire Services

Ingleside Scout Group

PO Box 1

Dee Why 2099

Hall Address:

ingleside

Exit Lights

Location	Tube/Diffuser	Battery	Pass	Date
Main Hall	Good	Good	Yes	28-02-17
Main Hall	Good	Good	Yes	28-02-17
Garage	Good	Good	Yes	28-02-17

Fire Equipment

Location	Type	Pass	Expiry Date	Date
Main Hall	ABE Powder	Yes	01-05-14	28-02-17
Main Hall	ABE Powder	Yes	01-05-14	28-02-17
Garage	ABE Powder	Yes	01-10-18	28-02-17
Kitchen	Blanket	Yes	NA	28-02-17

Smoke detector

Location	Type	Pass	Date
Main Hall	Battery	Yes	28-02-17
Main Hall	Battery	Yes	28-02-17
Main Hall	Battery	Yes	28-02-17
Rear Room	Battery	Yes	28-02-17
Den	Battery	Yes	28-02-17
Garage	Battery	Yes	28-02-17
Garage	Battery	Yes	28-02-17

Annual Fire Certificate Displayed: Yes

Evacuation procedure displayed: Yes

Emergency Contact numbers: Yes

Action Taken: Nil

SAMPLE CERTIFICATE

This work has been carried out by:

Licence No:

Paul Rumble

29009S

CERTIFICATION

I, the electrical contractor give notice to the customer that the work described in this Certificate has been completed in accordance with Australian Standards AS 1851, AS 2293, AS 1680, AS 3000, AS 3786, AS 2444, AS 1670 & OH & S Reg 2003.

Signature:



Address:

PO Box 344 Terrey Hills 2084

Date :

28-02-14

Telephone:

0413 081 991